

**TABLE 10-5**  
**DEFAULT U-FACTORS FOR ABOVE-GRADE WALLS**

**TABLE 10-5(4)**

**2 x 6 Single Wood Stud: R-19 Batt**

**NOTE:**

Nominal Batt R-value:  
R-19 at 6 inch thickness

Installed Batt R-value:  
R-18 in 5.5 inch cavity

Siding Material/Framing Type						
	Lapped Wood			T1-11		
R-value of Foam Board	STD	INT	ADV	STD	INT	ADV
0	0.062	0.058	0.055	0.065	0.061	0.058
1	0.058	0.055	0.052	0.060	0.057	0.055
2	0.054	0.052	0.050	0.056	0.054	0.051
3	0.051	0.049	0.047	0.053	0.051	0.049
4	0.048	0.046	0.045	0.050	0.048	0.046
5	0.046	0.044	0.043	0.048	0.046	0.044
6	0.044	0.042	0.041	0.045	0.044	0.042
7	0.042	0.040	0.039	0.043	0.042	0.040
8	0.040	0.039	0.038	0.041	0.040	0.039
9	0.038	0.037	0.035	0.039	0.038	0.037
10	0.037	0.036	0.035	0.038	0.037	0.036
11	0.036	0.035	0.034	0.036	0.035	0.035
12	0.034	0.033	0.033	0.035	0.034	0.033